KARNATAKA TEST HOUSE PVT. LTD.

MATERIAL TESTING LABORATORY

778/44, Gokul 1st Stage, 2nd Phase, 8th Cross, Triveni Road,
Yeshwanthpur, Bangalore - 560 054.
Tel.: 23378383 Telefax : 23375326, E-mail : kthblr@gmail.com Website : www.karnatakatesthouse.com

Report No. : KTH/G-II.AGG/2562-4399/2013-2014 **Date: 22.02.2014**

TEST REPORT ON GRADE II AGGREGATE
(Coarse Aggregate)

Name of the Customer*	:	**The Assistant Executive Engineer,** Shettyhalli Sub Division, BBMP, Bangalore.
Name of the Project*	:	Providing BS slab drain & metalling in kerekodi road near Nisarga layout at Abbigere in ward No.12.
Name of Contractor*	:	Mr. B.T. Ravikumar, Bangalore.
Source of Sample	:	Supplied by the Customer.
Sample Received on	:	18.02.2014.
Technical Reference	:	IS : 2386 (Part I to VIII)– 1963 (Reaffirmed-2002) and MORT&H-Specification for Road and Bridge work – 4th Revision 2001.

Sieve Analysis of Coarse Aggregate - 63mm to 45mm (Grade II)

Sl. No	Sieve size mm	% Passing	Specification as per MORT&H (Section 400, Table 400-6,7) % by wt. passing
1	90	100	100
2	63	93.2	90-100
3	53	62.8	25-75
4	45	15.0	0-15
5	22.4	-	0-5

* As furnished by the customer.

For **KARNATAKA TEST HOUSE PVT. LTD.**

(SREENIVASA.C)
TECHNICAL MANAGER

AE(L)

Note : 1) This report is not to be reproduced except in full without our prior permission in writing.
2) The results listed refer only to the tested samples and applicable parameters.

KARNATAKA TEST HOUSE PVT. LTD.

MATERIAL TESTING LABORATORY

778/44, Gokul 1st Stage, 2nd Phase, 8th Cross, Triveni Road,
Yeshwanthpur, Bangalore - 560 054.
Tel.: 23378383 Telefax : 23375326, E-mail : kthblr@gmail.com Website : www.karnatakatesthouse.com

Report No. : KTH/AGG/2562-4399a/2013-2014 **Date: 22.02.2014**

TEST REPORT ON GRADE III AGGREGATE
(Coarse Aggregate)

Name of the Customer* : **The Technical Manager - West,**
Kodigehalli Sub Division,
BBMP, Bangalore.

Name of the Project* : Providing BS slab drain & metalling in kerekodi road near Nisarga layout at Abbigere in ward No.12.

Name of Contractor* : Mr. B.T. Ravikumar, Bangalore.

Source of Sample : Supplied by the Customer.

Sample Received on : 18.02.2014.

Technical Reference : IS : 2386 (Part I to VIII)– 1963 (Reaffirmed-2002) and MORT&H-Specification for Road and Bridge work – 4th Revision 2001.

Sieve Analysis of Coarse Aggregate - 53mm to 22.4mm (Grade III)

Sl. No	Sieve size mm	% Passing	Specification as per MORT&H (Section 400, Table 400-6,7) % by wt. passing
1	63	100	100
2	53	96.2	95-100
3	45	67.4	65-90
4	22.4	1.8	0-10
5	11.2	-	0-5

* As furnished by the customer.

For KARNATAKA TEST HOUSE PVT. LTD.

(SREENIVASA.C)
TECHNICAL MANAGER

AE II

Note : 1) This report is not to be reproduced except in full without our prior permission in writing.
2) The results listed refer only to the tested samples and applicable parameters.